

Description

The **Vigil® Wireless Pull Station** is designed for use with the **Vigil® Wireless System**. Wireless Pull Stations are water resistant and suitable for mounting in resident rooms, dining rooms, bathing areas, and common areas. The Pull Station comes with red slide bar and 6-foot nylon pull string with weighted pendant. Vigil Wireless Pull Stations are supplied with a single gang surface mount wall box. The station may be flush mounted in a plastic wall box. Metal wall boxes may interfere with the wireless signal and are not approved for use.

Operation

To place a call, slide the red switch down or pull on the pull string until the switch slides to the on (down) position. When the Call Station receives confirmation from the system that the signal has been received, the LED will flash Green. The confirmation process usually takes less than one second. If for any reason the station is out of range, or the signal is not confirmed, the LED will flash Red to notify the user to try again. If the call is successful, the Green LED will continue to flash intermittently until the call is cancelled at the station. To cancel the call, the responding staff member resets the station by sliding the red switch back up.

When a Pull Station is activated, the signal is sent to the nearest receiver, which then sends a message to the Vigil Central Computer. The call is displayed on the Vigil® Active Calls Screen and is also sent to designated pagers or wireless phones. Using the Vigil® Calls software, the active calls can be displayed on any computer in the building that is on the facility's network. The call information displayed on the Active Calls Screen includes the type of call, the location of the station, the time the call was activated and the number of subsequent repeat calls that were sent if the call is not cancelled right away.



Features

- Intelligent Transceiver Technology
- Cancel at Origin of Call
- Visual Confirmation of Signal Reception
- Visual Indication when Station Active
- Visual Confirmation when Call Cancelled
- Long Life Battery
- Low Battery Alert

When the battery level drops to the minimum operating level, a Low Battery alert will be generated. The Low Battery alert will be displayed on the Vigil Calls screen and can also be sent to pagers or phones. See the *Specifications* section for battery details and instructions for replacing batteries.

Installation Instructions

Wireless pull stations are typically mounted in a single gang surface mount wall box. Follow the instructions below when installing a station:

1. Mount wall box on wall using suitable screws for the type of construction.
2. Insert battery into station observing correct polarity. Observe the LED's on the device. When the battery is first installed you will see the Green LED blink on and off for about 30 seconds followed by one longer blink and then a very short blink. This sequence indicates that the device has successfully found the network. If the station blinks RED refer to the Troubleshooting guide.
3. Record Serial # (Transmitter ID#) from back of device. Location of the serial number is shown below.
4. Screw mount the station to the wall box.

⚠️ Do not mount Wireless Stations on or near metal objects (HVAC, I Beams, etc) or electrical devices (motors, high voltage switching, etc) as they can interfere with the wireless signals

Location of serial number

The last six digits of the serial number ("142431" in the example) are needed when configuring the Vigil Central Computer.

The Splash antenna model 916-SP2 is permanently attached to the circuit board.

⚠️ Caution: Any changes or modifications not expressly approved by the party responsible for compliance could void the user's authority to operate the equipment.

To replace battery

Remove the station from the wall box. Replace with same battery type, observing polarity. Take care when handling the circuit board.



Specifications

PHYSICAL		ELECTRICAL	
Height	127mm (5.0")	Operating Voltage	3.3V
Width	83mm (3.26")	Wireless	900MHz FHSS Transceiver
Depth	38mm (1.5")	Standing Current	20µA
Weight	153 grams	Operating Current	40mA TX/RX
Enclosure	High impact white plastic enclosure	Battery Type	1/2AA 3.6V Lithium
Accessories	6 foot nylon pull string with weighted pendant	Battery Life	up to 4 years depending on usage
Temperature Ratings Operating: Storage/Transport	-0°C to 50°C (32°F to 122°F) -55°C to 85°C (-67°F to 185°F)		Manufactured in Canada
IC: 6706A-WNCA01 Operation is subject to the following two conditions: (1) this device may not cause interference, and (2) this device must accept any interference, including interference that may cause undesired operation of the device		FCC ID UI6-WNCA01 This Device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) This device may not cause harmful interference, and (2) This device must accept any interference received, including interference that may cause undesired operation.	